

UNIVERSITY OF MASSACHUSETTS AMHERST

RESIDENCE HALL / RESIDENTIAL FIRE INCIDENT LOG

* A fire incident is defined as any instance of open flame or other burning in a place not intended to contain the burning or in an uncontrolled manner.

2012

Date Reported	Time Reported	Date and Time of Occurance	Building / Address	Location	FD Response	Dollar Loss	Injuries or Fatality	Cause / Additional Details
11/21/2012	7:53am	Undertermined	James 660 Mass. Ave.	Room 200 Bathroom	No	0	0	Couple of small burnt papers in sink of bathroom found by maintainer cleaning.
11/19/2012	10:25pm	11/19/2012 10:25pm	Hamlin 739 N. Pleasant St.	3rd Floor residential room	Yes	0	0	Careless use of lighter. Towel within room caught fire. Fire extinguished with water from the room across the hall.
9/27/2012	3:36pm	9/27/2012 3:20pm	North Village Apartments 990 North Pleasant St.	Section J	No	Less than \$100	0	Cooking/ stovetop fire: Cooking oil from sauce pan leaked onto burner and ignited. Fire extinguished by can of fire suppressor hung from hood.
7/24/2012	12:05am	7/24/2012 12:05am	Greenough 120 Orchard Hill Rd.	Kitchen Room 106	Yes	0	0	Cooking fire: Ignited cooking oil. Occupant applied water to extinguish, increased smoke condition and activating fire alarm.
4/6/2012	10:00am	4/6/2012 10:00am	Chadbourne 110 Orchard Hill Rd.	Front and bathroom window.	No	0	0	Careless disposal of smoking materials caused woodchips in area near front of building to smolder and ignite. Damage to frame of window.
2/29/2012	10:00pm	2/29/2012 10:00pm	Prince 286 Sunset Ave.	Room 22	Yes	0	0	Trashcan fire: Undetermined cause, relocated by occupant to faucet and extinguished.
2/17/2012	8:25am	Undetermined	Hamlin 739 N. Pleasant St.	kitchenette 3rd floor	No	0	0	Received report of maliciously burnt paper and other items in kitchenette on 3rd floor.
2/6/2012	8:22pm	2/6/2012 8:22pm	Melville 650 Mass Ave.	1st Floor	Yes	0	0	Cooking/stovetop fire: Occupant left apartment with stove on. Smoke observed coming from under door, fire on stove area. Entry gained and fire extinguished with portable dry chemical extinguisher.